



Certificate of Compliance

Certificate: 1136976 (112526)

Master Contract: 162505

Project: 2341108

Date Issued: October 18, 2010

Issued to: M.B. Sturgis Inc.

555 Fee Fee Rd
St. Louis, MO 63043-3256
USA
Attention: Brian Diel

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



James A. Doherty

Issued by: James A. Doherty

PRODUCTS

CLASS 3312 01 - GAS CONVENIENCE OUTLETS AND ENCLOSURES

CLASS 3312 81 - GAS CONVENIENCE OUTLETS AND ENCLOSURES - Certified to U.S. Standards

CLASS 3305 87 - GAS ACCESSORY DEVICES - Quick Disconnect-Certified to U.S. Standards

CLASS 3305 07 - GAS ACCESSORY DEVICES - Quick Disconnect

CLASS 3312 01 - GAS CONVENIENCE OUTLETS AND ENCLOSURES

CLASS 3312 81 - GAS CONVENIENCE OUTLETS AND ENCLOSURES-Certified to U.S. Standards

Trade Name: COUPLE-SAFE

For Indoor/Outdoor Use (-40°F to 200°F)

Model Number:	Rated Pressure:	Inlet (inch):	Outlet (inch):
4/BV500C	5 PSI	1/2 NPT(F)	1/2 NPT(F)
5/BV750C	5 PSI	3/4 NPT(F)	3/4 NPT(F)



Certificate: 1136976 (112526)

Master Contract: 162505

Project: 2341108

Date Issued: October 18, 2010

CLASS 3305 07 - ACCESSORY DEVICES (GAS) Quick Disconnect

CLASS 3305 87 - ACCESSORY DEVICES (GAS) Quick Disconnect-Certified to U.S. Standards

Trade Name: COUPLE-SAFE

For Indoor/Outdoor Use (-40°F)

Model Number:	Rated Pressure:	Inlet (inch):	Outlet (inch):
4-F8	1/2 PSI	1/2 NPT(F)	1/2 NPT(F)
5-F12	1/2 PSI	3/4 NPT(F)	3/4 NPT(F)

APPLICABLE REQUIREMENTS

ANSI Z21.90-2001•CSA 6.24-2001 *Gas Convenience Outlets*

ANSI Z21.41-2003•CSA 6.9-2003 *Quick Disconnect Device Devices For Use With Gas Fuel Appliances*

ANSI Z21.41a-2005•CSA 6.9b-2005 *Addenda*

ANSI Z21.41b-2010•CSA 6.9b-2010 *Addenda*